

AENOR

Certificate of conformity Plastics

001/006647

Annex to Certificate

DESCRIPTION Trademark: ROMAFASER CT
Fiberglass content: 6%
Fiberglass content of the middle layer: 17%

| SERIE | DIAMETERS (mm) | APPLICATION CLASS / DESIGN PRESSURE (bar) | OPACITY |
|-------|--|--|---------|
| 3,2 | 20 - 25 | 1/10 ; 2/10 ; 4/10 ; 5/8 | Yes |
| 5,0 | 40 - 50 - 63 - 75 - 90 - 110 - 125 - 160 - 200 - 250 - 315 - 355 - 400 | 1/6 ; 2/6 ; 4/6 ; 5/4 | Yes |

First issued on 2016-11-07
Modified on 2018-09-18
Validity date 2021-11-07

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com