

AENOR

Certificate of conformity Plastics

001/006646

AENOR certifies that the organization

HELIROMA PLASTICOS, S.A.

registered office	ZONA INDUSTRIAL, EN-1 / IC-2, KM 250,5 3850-184 ALBERGARIA-A-VELHA (Portugal)
supplies	Polypropylene random with modified cristallinity pipes (PP-RCT) and glass fiber (PP-RCT)/PP-RCT+GF /PP-RCT) for installation of hot and cold water inside the building structure
in compliance with	TECHNICAL SPECIFICATION TO RP 001.78
DESCRIPTION	Trademark: ROMAKLIMA CT Fiberglass content: 6% Fiberglass content of the middle layer: 17% See annex for more information.
Production site	ZONA INDUSTRIAL, EN-1 / IC-2, KM 250,5 3850-184 ALBERGARIA-A-VELHA (Portugal)
Certification scheme	In order to grant this Certificate, AENOR has tested the product and has verified the quality system implemented for its manufacture. AENOR performs these tasks periodically while the Certificate has not been cancelled, in accordance with Specific Rules RP 01.78. This certificate supersedes 001/006646, dated 2017-11-24
First issued on	2016-11-07
Modified on	2018-05-09
Validity date	2021-11-07



Rafael GARCÍA MEIRO
Chief Executive Officer

Original Electronic Certificate

AENOR

Certificate of conformity Plastics

001/006646

Annex to Certificate

DESCRIPTION Trademark: ROMAKLIMA CT
Fiberglass content: 6%
Fiberglass content of the middle layer: 17%

SERIE	DIAMETERS (mm)	APPLICATION CLASS / DESIGN PRESSURE (bar)	OPACITY
8,0	125 - 160 - 200 - 250 - 315 - 355 - 400	1/4 ; 2/4 ; 4/4	Yes

First issued on 2016-11-07
Modified on 2018-05-09
Validity date 2021-11-07

Original Electronic Certificate

AENOR INTERNACIONAL S.A.U.
Génova, 6. 28004 Madrid. España
Tel. 91 432 60 00.- www.aenor.com